



## **Addendum No. 1**

City of Coquitlam

**RFP No. 24-058**

### **Parks Lighting Study and Lighting Condition Assessments**

Issue Date: June 21, 2024

Total Page Count: 1

Proponents shall note the following amendments to the RFP documents:

#### **QUESTIONS AND CLARIFICATIONS**

Q1. Regarding the "Condition Assessment" of the pole standards, is this a visual assessment and recommendation or is a more comprehensive review required as part of this RFP deliverables (i.e. Ultrasonic Thickness testing etc.) for each pole?

**A1. The Consultant should propose and clearly state their proposed methods to meet the objectives of the RFP, and can price optional additional services if necessary. The City suggests that a triage approach might be logical; such as, depending on the visual assessment, further non-destructive testing may be appropriate to accurately characterize assets and ensure the City can continue safe operation of the system.**

---

#### ***End of Addendum No. 1***

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

*Issued by:*

M. Pain

Procurement Manager

[bid@coquitlam.ca](mailto:bid@coquitlam.ca)