



## **Addendum No. 1**

City of Coquitlam

**RFP No. 24-092**

### **Town Centre Fire Hall Generator Replacement**

Issue Date: December 9, 2024

Total Page Count: 1

Proponents shall note the following amendments to the RFP documents:

#### **QUESTIONS AND CLARIFICATIONS**

Q1. We request approval for the following generator:  
mtu 4R0113 DS100 Diesel Generator Set  
100 kWe/60 Hz/Standby/208 - 600V

**A1. Yes this generator is an acceptable alternative.**

---

#### ***End of Addendum No. 1***

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

*Issued by:*

Chris Overes  
Senior Procurement Specialist  
[bid@coquitlam.ca](mailto:bid@coquitlam.ca)