



Addendum No. 2

City of Coquitlam

RFP No. 25-043

Robinson Memorial Park Cemetery - Phase 2 Columbarium Walls Design Build

Issue Date: March 28, 2025

Total Page Count: 1

Proponents shall note the following amendments to the RFP documents:

QUESTIONS:

- Q1. Columbarium Design – Single-Sided vs. Double-Sided - The RFP specifies a columbarium, and based on the provided information, one side will face Robinson Street. Please confirm whether a single-sided columbarium is required, or if a double-sided columbarium would be considered to allow visibility from the street.
- A1. Double-sided walls are acceptable. Proposals will be evaluated as described in the RFP, including demonstrated functionality, efficient use of space, aesthetic, and harmony with surroundings.**
- Q2. Niche Size - The standard niche size available is 12" Wide x 12" High x 16" Deep. Please confirm if this size is acceptable or if customization is required.
- A2. This size is acceptable.**
- Q3. Granite Shutter Thickness - The RFP specifies a minimum granite shutter thickness of ½". The standard thickness available is ¾". Please confirm if this is acceptable.
- A3. ¾" is an acceptable thickness.**

End of Addendum No. 2

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

Issued by:

Chris Overes
Senior Procurement Specialist
bid@coquitlam.ca