



Addendum No. 1
City of Coquitlam
Tender No. 89120
Falcon and Pinetree Way PRV Rehabilitation
 (Consists of 2 Pages)
 Issue Date: June 15, 2026

Tenderers shall note the following changes:

Revisions

1. Refer to: INSTRUCTIONS TO TENDERERES

Additional Instructions to Tenderers
Add Sub-Clause 4.0 (a) as follows:

4.0 (a) Non-Mandatory Site Meeting

A site meeting will be held to visit both PRV stations as per the following details:

Location:

1. Falcon PRV: Near Falcon Drive and Guildford Way intersection, all participants should gather near Flacon PRV at Guilford/Falcon intersection; and
2. Pinetree Way PRV: Near 1619 Pinetree Way

Date: Monday, June 22, 2026

Time: Starting at 10:00 AM at the Falcon PRV

Bidders should come with harnesses, steel toe boots, vests and hard hats if they wish to enter the chambers. City will supply the gas detection equipment, blower and confined space entry permit. Any site-related questions will need to be submitted to bid@coquitlam.ca before the inquiry deadline as listed in Instructions to Tenderers Clause (1.2).

Questions & Clarifications

Q1) Please confirm if the roofs/lids of the PRV chambers are tied integrally to the walls of the PRV chambers.

A1) The chambers appear to be cast in place with roof tied to walls.

- Q2) Please confirm if bypasses are required.
- A2) The Pinetree Way PRV can be shut down for the duration of the construction but the Falcon PRV will require a bypass to ensure that the residents to the North of the PRV on Falcon aren't out of water.**
- Q3) Please provide waterworks and PRV asbuilts for the Pinetree Way PRV
- A3) Watermain asbuilt available at:
<https://publicdocs.coquitlam.ca/CoquitlamDoc/getdocIF.asp?doc=337683>
The City does not have an asbuilt for the Pinetree Way PRV.**

End of Addendum No. 1

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and should be acknowledged on the Tender form where indicated.

Upon submitting a Tender, Tenderers will be deemed to have received all addenda and considered the information for inclusion in the Tender submitted.

Issued by:

M. Pain
Manager Procurement
Email: bid@coquitlam.ca